

DO NOT SCALE DRAWINGS. VERIFY ALL DIMENSIONS and clearances from ARCHITECTURAL, STRUCTURAL, slope and other appropriate drawings or at site. Lay out and coordinate

- |   |   |
|---|---|
| 1 | REMOVE EXISTING CHILLER AND ASSOCIATED PIPING AND CONTROLS. RECOVER R-42 REFRIGERANT AND DELIVER TO OWNER. THE EXISTING CONCRETE PAD SHALL REMAIN.  |
| 2 | REMOVE EXISTING AIR-COOLED CONDENSERS LOCATED ON GRADE AND ASSOCIATED REFRIGERANT PIPING AND CONTROLS. THE EXISTING CONCRETE PAD SHALL REMAIN.  |
| 3 | REMOVE EXISTING UNDERGROUND REFRIGERANT PIPING AND UNDERGROUND PVC PROTECTIVE CONDUIT PIPING AND SAGRELL.   |
| 4 | REMOVE EXISTING 8" CMU WALL AND DOOR TO ALLOW FOR THE MECHANICAL ROOM EXPANSION AS SHOWN ON SHEET M01.  |
| 5 | ROUTE ALL EQUIPMENT FROM THE FIRST FLOOR TO THE BASEMENT VIA THE EXIST ELEVATOR. THE MECHANICAL CONTRACTOR SHALL PROVIDE TEMPORARY PADDING TO PROTECT THE INTERIOR ELEVATOR FINISHES THROUGH THE CONSTRUCTION OF THE PROJECT. |
| 6 | SEAL CFT GORE FOR INSTALLATION OF NEW SANITARY AND VENT PIPING. VERIFY LOCATION OF ALL FOOTINGS WITH OWNER PRIOR TO CUTTING FLOOR.  |
| 7 | RETURN ITEM TO OWNER ONCE REMOVED.  |



**Alvine  
Engineering**

| Oma:  | Lincoln:  | Oklahoma City:  | Des Moines:  |
|---|---|---|--|
| 1102 Dodge on the Mall<br>Oma, Nebraska 68102 | 1800 O Street, Suite 104<br>Lincoln, Nebraska 68508 | 1343 Broadway Extension, Suite 101<br>Oklahoma City, Oklahoma 73114 | 400 East Court Ave., Suite 330<br>Des Moines, Iowa 50309 |
| Phone: (402) 344-7007                         | Phone: (402) 471-6161                               | Phone: (405) 924-4800   | Phone: (515) 242-6589                                    |
| Fax: (402) 344-9376                           | Fax: (402) 477-9816                                 | Fax: (405) 751-6567   | Fax: (515) 242-1155                                      |
| <b>File Name</b>                              |   |   |  |

|       |              |
|-------|--------------|
| PAB   | 20123192M010 |
| Drawn | Project No.  |

|             |     |         |
|-------------|-----|---------|
| 20123192    | CAE | Checked |
| Drawing No. |     |         |

STA \_\_\_\_\_ Date \_\_\_\_\_ MO10

|         |            |  |
|---------|------------|--|
| 5/20/13 | 05/20/2013 |  |
|---------|------------|--|